

ICC-ES Evaluation Report

ESR-3145

Reissued February 2026

This report also contains:

- CA Supplement



Subject to renewal February 2027

- FL Supplement

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.



Copyright © 2026 ICC Evaluation Service, LLC. All rights reserved.

<p>DIVISION: 05 00 00—METALS</p> <p>Section: 05 05 23—Metal Fastenings</p> <p>DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES</p> <p>Section: 06 05 23—Wood, Plastic, and Composite Fastenings</p>	<p>REPORT HOLDER:</p> <p>AEROSMITH FASTENING SYSTEMS</p> 	<p>EVALUATION SUBJECT:</p> <p>AEROSMITH BRAND FASTENERS</p>	
---	--	---	---

1.0 EVALUATION SCOPE

Compliance with the following codes:

- 2021, 2018 and 2015 [International Building Code® \(IBC\)](#)
- 2021, 2018 and 2015 [International Residential Code® \(IRC\)](#)

Property evaluated:

- Structural

2.0 USES

Aeromsmith Brand Fasteners are used to attach wood structural panels to cold-formed steel wall framing for shear wall applications under the IBC, to resist in-plane wind or seismic forces in Seismic Design Categories A and B, in Occupancy Categories I through IV. The fasteners may be used in structures regulated under the IRC when an engineered design is submitted in accordance with IRC Section R301.1.3.

3.0 DESCRIPTION

3.1 Aeromsmith Brand Fasteners:

The Aeromsmith Brand Fasteners are power-actuated fasteners with dimensions as shown in [Table 1](#). The fasteners are formed from steel wire complying with ASTM A510 Grade 1060 and heat-treated to a Rockwell C core hardness of 52 to 55. The fasteners have a straight, knurled shank with a nominal diameter of 0.1 inch (2.5 mm) and a flat head with a nominal dimension of 0.3 inch (7.9 mm). The standard fasteners are galvanized in accordance with ASTM B633, Type 1, SC 1; or ASTM B695, Type 1, Class 5. The fasteners are also available with a nickel alloy plating, designated by the letter “G” in the suffix of the product number. Fasteners are supplied in collated coils or strips.

3.2 Shear Wall Assemblies:

3.2.1 General: Recognized shear wall assemblies are constructed of wood structural panels attached to one side of cold-formed steel framing using the Aerosmith Brand Fasteners. At each end of the shear wall and at interior panel joints, a double stud must be used. Each double stud must be comprised of two studs placed web-to-web and fastened together as shown in [Figure 2](#). Intermediate studs must be spaced no more than 24 inches (610 mm) on center. All studs must be fastened to the tracks with one screw through each stud flange. Wood panels must have a minimum width of 12 inches (305 mm). One hold-down must be installed at each end of the shear wall, and the bottom wall track must be attached to the supporting structure.

3.2.2 Wood Structural Panels: Wood structural panels must be $^{15}/_{32}$ -inch-thick (11.9 mm) Exposure 1 plywood sheathing with a minimum span rating of 32/16, complying with DOC PS-1; or $^{7}/_{16}$ -inch-thick (11.1 mm) Structural 1 OSB sheathing complying with DOC PS-2, as indicated in [Table 2](#).

3.2.3 Cold-formed Steel (CFS) Framing Members: CFS framing members must be formed from steel complying with ASTM A1003, Grade 50, Type H (ST50H); or ASTM A653 SS, Grade 50, with a minimum G60 coating. CFS wall studs must be C-shaped members with a thickness designation as shown in [Table 2](#). The studs must have a minimum flange width of $1^{5}/_{8}$ inches (41 mm), a minimum nominal depth of $3^{1}/_{2}$ inches (89 mm) and a minimum flange stiffener (lip) length of $^{3}/_{8}$ inch (9.5 mm). The CFS tracks must be channel-shaped members with a thickness designation as shown in [Table 2](#). The tracks must have a minimum flange width of $1^{1}/_{4}$ inches (32 mm) and a minimum nominal depth of $3^{1}/_{2}$ inches (89 mm).

3.2.4 Framing Fasteners: Screws used to join doubled studs together and to fasten tracks to studs must be minimum #8-18 pan head, self-drilling, tapping screws complying with ASTM C1513 or recognized in an ICC-ES evaluation report. The screws must have lengths sufficient to penetrate a minimum of three threads past the receiving member.

4.0 DESIGN AND INSTALLATION

4.1 Design:

Recognized shear wall assemblies are alternatives to the Type I shear walls prescribed in Section B5.2.2.3.3 of AISI S240 and Section E1.3 of AISI S400 (Section C2 of AISI S213 for the 2015 IBC) and must comply with all applicable requirements of Section B5.2 of AISI S240 and Section E1 of AISI S400 (Section C2 of AISI S213 for the 2015 IBC). The shear walls are limited to a maximum height-to-width aspect ratio of 2:1.

For seismic design, the response modification coefficient, R , the system overstrength factor, Ω_o , and the deflection amplification factor, C_d , must be no greater than 3. Available unit shear strengths for shear walls subjected to short-term loads due to wind or seismic forces are shown in [Table 2](#). For shear loads of normal and permanent load durations, defined by the AWC National Design Specification for Wood Construction (NDS), the tabulated values must be multiplied by 0.63 and 0.56, respectively.

Hold-downs and chord studs must be able to resist the wind or seismic uplift load at the end of the wall. Fasteners or anchors must attach the bottom wall track to the supporting structure at a maximum of 4 feet (1220 mm) on center and must be capable of transferring the applied shear from the bottom wall track to the supporting structure.

Horizontal deflection of the shear walls due to the applied shear load may be calculated using the following equations, as applicable:

$$\delta = \frac{8vh^3}{E_s A_c b} + \omega_1 \omega_2 \frac{vh}{\rho G t_{sheathing}} + \omega_3 \left(-1.5 + 0.082s + \frac{0.071}{t_{stud}} + \frac{v^2}{2,690,000} + \frac{900}{F_e} \right) + \frac{h}{b} \delta_v$$

For SI:

$$\delta = \frac{8vh^3}{E_s A_c b} + \omega_1 \omega_2 \frac{vh}{\rho G t_{sheathing}} + \omega_3 \left(-37.8 + 0.082s + \frac{45.99}{t_{stud}} + \frac{v^2}{22.59} + \frac{152}{F_e} \right) + \frac{h}{b} \delta_v$$

The variables and constants in the equations are defined in Section B5.2.5 of AISI S240 and E1.4.1.4 of AISI S400 (Section C2.1.1 of AISI S213 for the 2015 IBC), with the following exceptions:

- Values for $G t_{sheathing}$ may be taken from IBC Table 2305.2(2).
- F_e is the dowel bearing strength and is equal to 4650 psi (32.06 MPa) for plywood and 6000 psi (41.37 MPa) for OSB.

4.2 Installation:

The Aerosmith Brand Fasteners must be installed in accordance with the Aerosmith published installation instructions, the approved plans and this report. A copy of the Aerosmith published installation instructions and the approved plans must be available on the jobsite at all times during fastener installation.

The wood structural panels must be attached to the framing with the Aerosmith Brand Fasteners spaced as noted in [Table 2](#). The Aerosmith Brand Fasteners must be installed using a pneumatic or fuel-powered tool, as recommended by Aerosmith. The fasteners must be driven flush with the face of the wood panel and must penetrate the steel framing a minimum of $\frac{5}{16}$ inch (7.9 mm). Fasteners must be installed a minimum of $\frac{3}{8}$ inch (9.5 mm) from the edge of the wood panel. At doubled studs at the end of the wall, the fasteners must be staggered between the two studs as shown in [Figure 3](#).

Fasteners must be installed in dry, interior locations. In accordance with IBC Section 2304.10.6.4 (Section 2304.10.5.4 for the 2018 and 2015 IBC) and the Exception to IBC Section 2304.10.6.1 (Section 2304.10.5.1 for the 2018 and 2015 IBC), the nickel alloy plated Aerosmith fasteners may be used in SBX/DOT and zinc borate preservative-treated wood and fire-retardant-treated wood, based on the Aerosmith recommendations.

Hold-downs, track anchors, and other connections to the shear walls must be installed in accordance with the approved plans.

4.3 Special Inspection:

Special Inspections are required for the fastening and anchoring of the shear walls, in accordance with 2021 IBC Sections 1705.1.1, 1705.12.2 including Exception 2 and 1705.13.3 including Exception 2 (2018 and 2015 IBC Sections 1705.1.1, 1705.11.2 including Exception 2 and 1705.12.3 including Exception 2) for wind and seismic resistance, respectively. When special inspections are required, a statement of special inspections must be submitted to the code official in accordance with IBC Section 1704.3.

5.0 CONDITIONS OF USE:

The Aerosmith Brand Fasteners described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 The fasteners are manufactured and identified in accordance with this report.
- 5.2 The other components of the shear walls must comply with this report, the applicable code and applicable ICC-ES evaluation reports.
- 5.3 Fastener installation complies with this report and the Aerosmith instructions. In the event of conflict between this report and Aerosmith published instructions, the more restrictive requirements govern.
- 5.4 Installation is limited to Seismic Design Categories A and B.
- 5.5 Installation is limited to structures four stories [65 feet (19.8 m)] or less in height, with interior walls, partitions, ceilings and exterior wall systems that have been designed to accommodate the story drifts.
- 5.6 The aspect ratio (wall height/wall length) of the shear wall must not exceed 2:1. Shear walls with greater aspect ratios are outside the scope of this report.
- 5.7 Type II shear walls constructed with the Aerosmith Brand Fasteners are outside the scope of this report.
- 5.8 Calculations demonstrating that the applied in-plane shear loads are less than the available shear wall strength must be submitted to the code official for approval. The calculations must be prepared by a registered design professional where required by the statutes of the jurisdiction in which the project is to be constructed.
- 5.9 Calculations and details showing that the sheathing, the CFS framing and the foundation anchorage are adequate to resist the applied transverse loads, and comply with the applicable provisions in AISI S240 and AISI S400 (AISI S213 for the 2015 IBC), must be submitted to the code official. The CFS framing must also be adequate to support the applied gravity loads. These calculations and details must be signed and sealed by a registered design professional, when required by the statutes of the jurisdiction in which the project is to be constructed.
- 5.10 Calculations and details must be submitted to the code official showing how the lateral loads are transferred from the roof or floor diaphragm into the shear wall. These calculations and details must be signed and sealed by a registered design professional, when required by the statutes of the jurisdiction in which the project is to be constructed.
- 5.11 When the shear wall assemblies are used above the first story, calculations and details must be submitted to the code official showing the load path for the transfer of lateral and overturning forces from the upper

story shear walls to the foundation. These calculations and details must be signed and sealed by a registered design professional, when required by the statutes of the jurisdiction in which the project is to be constructed.

- 5.12 An approved weather-resistant exterior wall envelope must be installed to protect weather-exposed surfaces (defined in IBC Section 202 and IRC Section R703) of the wood structural panels.
- 5.13 Use of fasteners in contact with preservative-treated or fire-retardant-treated wood is not allowed, except for nickel alloy plated fasteners installed as described in Section 4.2.
- 5.14 The Aerosmith fasteners are manufactured under a quality control program with inspections by ICC-ES.

6.0 EVIDENCE SUBMITTED

- 6.1 Static load test data in accordance with ASTM E564.
- 6.2 Data in accordance with the [ICC-ES Acceptance Criteria for Power-actuated Fasteners for Shear Wall Assemblies Constructed with Cold-formed Steel Framing and Wood Structural Panels \(AC230\)](#), dated October 2018 (editorially revised February 2021).

7.0 IDENTIFICATION

7.1 The ICC-ES mark of conformity, electronic labeling, or the evaluation report number (ICC-ES ESR-3145) along with the name, registered trademark, or registered logo of the report holder must be included in the product label.

7.2 Fasteners:

In addition to Section 7.1, each package of fasteners must be labeled with the fastener designation, report holder’s name (Aerosmith). Packages of nickel alloy plated fasteners are also identified by the words “PT2000”. The head of each fastener is imprinted with one of the marks shown in [Figure 1](#).

7.3 CFS:

In addition to Section 7.1, each CFS stud and track must be identified with the minimum base steel thickness in decimal inches or mils, the minimum specified yield strength, and the galvanized coating designation.

7.4 Wood Structural Panels:

In addition to Section 7.1, each wood structural panels must be identified in accordance with DOC PS-1 or DOC PS-2, as applicable.

7.5 Hold-downs:

In addition to Section 7.1, each hold-downs must be identified in accordance with an applicable ICC-ES evaluation report.

7.6 The report holder’s contact information is the following:

AEROSMITH FASTENING SYSTEMS
5621 DIVIDEND ROAD
INDIANAPOLIS, INDIANA 46241
(317) 243-5959
www.aerosmithfastening.com

TABLE 1—AEROSMITH BRAND FASTENERS

FASTENER DESIGNATION	NOMINAL SHANK DIAMETER (in.)	FASTENER LENGTH (in.)	HEAD DIAMETER (in.)	SHANK STYLE
2255Z	0.1	1.00	0.3	Knurled
2325Z	0.1	1.25	0.3	Knurled
2385Z	0.1	1.50	0.3	Knurled
2505Z	0.1	2.00	0.3	Knurled
2635Z	0.1	2.50	0.3	Knurled

For SI: 1 inch = 25.4 mm.

TABLE 2—AVAILABLE STRENGTHS FOR SHEAR WALLS SUBJECTED TO SEISMIC LOADS OR WIND LOADS^{1,2,3,4,5}

FASTENER	WOOD STRUCTURAL PANEL	MINIMUM FRAMING THICKNESS DESIGNATION (mils)	SPACING OF FASTENERS AT PERIMETER OF WOOD PANEL (inches)	NOMINAL UNIT SHEAR STRENGTH ⁶ (lbf/ft)	OCCUPANCY CATEGORY	ALLOWABLE SEISMIC UNIT SHEAR STRENGTH (ASD) ⁷ (lbf/ft)	DESIGN SEISMIC UNIT SHEAR STRENGTH (LRFD) ⁷ (lbf/ft)	ALLOWABLE WIND UNIT SHEAR STRENGTH (ASD) ⁷ (lbf/ft)	DESIGN WIND UNIT SHEAR STRENGTH (LRFD) ⁷ (lbf/ft)	
2255Z 2325Z 2385Z 2505Z 2635Z	1 ⁵ / ₃₂ " Plywood	54	2	1653	I or II	602	903	819	1065	
					III	655	982			
					IV	661	991			
	1 ⁵ / ₃₂ " Plywood	54	4	—	—	I or II	462	693	623	809
						III	498	747		
						IV	501	752		
	1 ⁵ / ₃₂ " Plywood	54	6	6	853	I or II	322	483	427	554
						III	341	512		
						IV	341	512		
	7/16" OSB	54	2	2	1608	I or II	611	916	804	1045
						III	643	964		
						IV	643	964		
	7/16" OSB	54	4	4	—	I or II	464	696	604	786
						III	484	725		
						IV	484	725		
	7/16" OSB	54	6	6	811	I or II	317	476	405	527
						III	324	486		
						IV	324	486		
	7/16" OSB	43	4	4	1011	I or II	405	607	506	657
						III	405	607		
						IV	405	607		
	7/16" OSB	68	2	2	1912	I or II	765	1147	956	1243
						III	765	1147		
						IV	765	1147		

For SI: 1 inch = 25.4 mm, 1 lbf/ft = 14.6 N/m, 1 ksi = 6.895 Mpa.

¹Studs shall have a minimum specified yield strength of 50 ksi and shall be spaced a maximum of 24 inches on center.

²Tabulated values are for short-term loads due to seismic forces. For shear loads of normal and permanent load duration as defined by the NDS, the tabulated values must be multiplied by 0.63 and 0.56, respectively.

³Fasteners must penetrate a minimum of 5/16 inch through the steel framing.

⁴Fasteners must be spaced a maximum of 12 inches on center in the field of the panels.

⁵Thicker wood structural panels may be used, provided the required fastener penetration is achieved, but provide no increase in available unit shear strength.

⁶Nominal unit shear strength is the average tested peak strength for the assembly, adjusted for the cold-formed steel framing properties in accordance with Section 3.3.4 of ICC-ES AC230. A "—" indicates the assembly was not tested. Available strengths have been determined by interpolation between results for tested configurations.

⁷Allowable and design strengths have been derived in accordance with ICC-ES AC230.

TABLE 3—ULTIMATE STATIC LOAD FOR SHEAR RESISTANCE (ASTM E564 TESTING)^{1,2,3,4,5}

FASTENER	WOOD STRUCTURAL PANEL	MINIMUM FRAMING THICKNESS DESIGNATION (mils)	SPACING OF FASTENERS AT PERIMETER OF WOOD PANEL (inches)	ULTIMATE SHEAR STRENGTH ⁶ (lb/ft)
2255Z 2325Z 2385Z 2505Z 2635Z	¹⁵ / ₃₂ " Plywood	54	2	2193
	¹⁵ / ₃₂ " Plywood	54	4	1597 ⁵
	¹⁵ / ₃₂ " Plywood	54	6	1002
	⁷ / ₁₆ " OSB	54	6	997
	⁷ / ₁₆ " OSB	43	4	1327

For SI: 1 inch = 25.4 mm, 1 lb/ft = 14.6 N/m, 1 ksi = 6.895 Mpa.

¹Studs shall have a minimum specified yield strength of 50 ksi and shall be spaced a maximum of 24 inches on center.

²Fasteners must be spaced a maximum of 12 inches on center in the field of the panels.

³A Simpson Strong-Tie model HTT4 Tension Tie (or equivalent) is required at both ends of the wall and must be installed per manufacturer's installation instructions.

⁴CFS framing shall comply with ICC-ES AC 230 Section 3.3 for grades, dimensions, yield and tensile strength.

⁵This value has not been tested and available strengths have been determined by interpolation between results for tested configurations.

⁶The maximum aspect ratio is 2:1.

⁷The sheathing is to be installed vertically with a double stud at each sheathing seam (at 48" o.c.).




FIGURE 1—HEAD MARKINGS FOR AEROSMITH BRAND FASTENERS




FIGURE 2—FASTENING PATTERN FOR DOUBLED STUDS




FIGURE 3—FASTENING PATTERNS FOR WOOD STRUCTURAL PANELS ATTACHED TO DOUBLED STUDS AT WALL ENDS

DIVISION: 05 00 00—METALS

Section: 05 05 23—Metal Fastenings

DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES

Section: 06 05 23—Wood, Plastic, and Composite Fastenings

REPORT HOLDER:

AEROSMITH FASTENING SYSTEMS

EVALUATION SUBJECT:

AEROSMITH BRAND FASTENERS

1.0 REPORT PURPOSE AND SCOPE**Purpose:**

The purpose of this evaluation report supplement is to indicate that Aerosmith Brand Fasteners, described in ICC-ES evaluation report [ESR-3145](#), have also been evaluated for compliance with the codes noted below.

Applicable code editions:

- 2022 California Building Code (CBC)

For evaluation of applicable Chapters adopted by the California Office of Statewide Health Planning and Development (OSHPD) AKA: California Department of Health Care Access and Information (HCAI) and the Division of State Architect (DSA), see Sections 2.1.1 and 2.1.2 below.

- 2022 California Residential Code (CRC)

2.0 CONCLUSIONS**2.1 CBC:**

The Aerosmith Brand Fasteners, described in Sections 2.0 through 7.0 of the evaluation report [ESR-3145](#), comply with CBC Chapters 22 and 23, provided the design and installation are in accordance with the 2021 *International Building Code*® (IBC) provisions noted in the evaluation report and the additional requirements of the CBC Chapters 16, 17, 22 and 23, as applicable.

2.1.1 OSHPD:

The applicable OSHPD Sections and Chapters of the CBC are beyond the scope of this supplement.

2.1.2 DSA:

The applicable DSA Sections and Chapters of the CBC are beyond the scope of this supplement.

2.2 CRC:

The Aerosmith Brand Fasteners, described in Sections 2.0 through 7.0 of the evaluation report [ESR-3145](#), comply with the CRC Chapter 3, provided the design and installation are in accordance with the 2021 *International Residential Code*® (IRC) provisions noted in the evaluation report, and the additional requirements of CRC Chapter 3 and 7, as applicable.

This supplement expires concurrently with the evaluation report, reissued February 2026.

DIVISION: 05 00 00—METALS

Section: 05 05 23—Metal Fastenings

DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES

Section: 06 05 23—Wood, Plastic, and Composite Fastenings

REPORT HOLDER:**AEROSMITH FASTENING SYSTEMS****EVALUATION SUBJECT:****AEROSMITH BRAND FASTENERS****1.0 REPORT PURPOSE AND SCOPE****Purpose:**

The purpose of this evaluation report supplement is to indicate that Aerosmith Brand Fasteners, described in ICC-ES evaluation report [ESR-3145](#), have also been evaluated for compliance with the codes noted below.

Applicable code editions:

- 2023 Florida Building Code—Building
- 2023 Florida Building Code—Residential

2.0 CONCLUSIONS

The Aerosmith Brand Fasteners, described in Sections 2.0 through 7.0 of the evaluation report [ESR-3145](#), comply with the *Florida Building Code—Building* and the *Florida Building Code—Residential*. The design requirements must be determined in accordance with the *Florida Building Code—Building* or the *Florida Building Code—Residential*, as applicable. The installation requirements noted in ICC-ES evaluation report [ESR-3145](#) for the 2021 *International Building Code*® meet the requirements of the *Florida Building Code—Building* or the *Florida Building Code—Residential*, as applicable, with the following condition:

- In accordance with *Florida Building Code—Building* Section 2304.10.5.4 and the Exception to *Florida Building Code—Building* Section 2304.10.5.1, the nickel alloy plated Aerosmith fasteners may be used in SBX/DOT and zinc borate preservative-treated wood and fire-retardant-treated wood, based on the Aerosmith recommendations.

Use of the Aerosmith Brand Fasteners for compliance with the High-Velocity Hurricane Zone provisions of the *Florida Building Code—Building* and the *Florida Building Code—Residential* has not been evaluated, and is outside the scope of this supplemental report.

For products falling under Florida Rule 61G20-3, verification that the report holder's quality assurance program is audited by a quality assurance entity approved by the Florida Building Commission for the type of inspections being conducted is the responsibility of an approved validation entity (or the code official when the report holder does not possess an approval by the Commission). Florida Rule 61G20-3 is applicable to products and/or systems which comprise the building envelope and structural frame for compliance with the structural requirements of the Florida Building Code.

This supplement expires concurrently with the evaluation report, reissued February 2026.