

TAG NUMBER	DESCRIPTION
CY-(ALL)	SOLENOID VALVE, NUMATICS L01SA4590 (120V AC)
FY-(ALL)	TRANSUDCER, 0-15PSI = 4-20mA SENSYCON 22/06-65
LY-(ALL)	SOLENOID VALVE, NUMATICS L01SA4590 (120V AC)
TT-(ALL)	RTD TRANSMITTER, ROSEMOUNT 3144D1K5B4C2Q4 (0-100°C)
XY-(ALL)	SOLENOID VALVE, NUMATICS L01SA4590 (120V AC)
PUMP-001	PUMP, 2.5"X2"TC FRISTAM FPX-1742/190mm RELIANCE XEX 30 HP 3540 RPM EXPLOSION PROOF
JY-001	MOTOR STARTER, ALLEN BRADLEY 100-SERIES CONTACTOR W/ 140-SERIES OVERLOAD
FV-002	VALVE, .75"TC MODULATING DIAPHRAGM IIT 3/4"-F-419-6-R2-36-A209-PR4-SR1
FV-003	VALVE, 1.5"TC MODULATING DIAPHRAGM IIT 1 1/2"-F-419-6-TM17-36-M7-A217-HW3-PR4-SR1
HEATER-004	ELECTRIC HEATER, 3"TC 15KW ASB PFSU-24958 ER EXPLOSION PROOF
JY-004A	CONTACTOR, ALLEN BRADLEY 100C SERIES
JY-004B	HEATER POWER CONTROLLER, WATLOW DB20-60K2-0000
TE-005	RTD, 1.5"TC SINGLE ELEMENT ROSEMOUNT 680P11U025L150X8Q4
PI-006	PRESSURE GUAGE, 1.5"TC ANDERSON EB-074-01-004-4-0-4-3 (0-160 PSI)
XV-007	VALVE, .5"TC DIAPHRAGM IIT 1/2"-F-419-6-R2-36-A206
FE-008	FLOW SENSOR, 2"TC MASS CORIOLIS MICRO MOTION H200S352NCAMEZZZ
FIT-008	FLOW TRANSMITTER, MICRO MOTION 1700I11DBMEZZX (0-150 GPM)
XV-009	VALVE, 1"TC DIAPHRAGM IIT 1"-F-419-6-TM17-36-M7-A209
XV-010	VALVE, 2"TC DIAPHRAGM IIT 2"-F-419-6-TM17-36-M7-A217
CHECK-011	CHECK VALVE, 3"TC WAUKESHA 45BYP-3"
CE-011	CONDUCTIVITY PROBE, 2"TC ROSEMOUNT 225-07-56
CIT-011	CONDUCTIVITY TRANSMITTER, ROSEMOUNT XMT-T-HT-10-67 (0-200mS/cm)
CE-012	CONDUCTIVITY PROBE, 1.5"TC ROSEMOUNT 403-12-20-54
CIT-012	CONDUCTIVITY TRANSMITTER, ROSEMOUNT XMT-C-HT-10-67 (0-2000uS/cm)
XV-013	VALVE, .5"TC DIAPHRAGM IIT 1/2"-F-419-6-TM17-36-M7-A206
TE-014	RTD, 2"TC SINGLE ELEMENT ROSEMOUNT 680P11U025L200X8Q4
EDUCTOR-015	EDUCTOR, 2.5" ADVANCE 120A012
LC-101	LEVEL PROBE, 1.5" MILLTRONICS C-235-S3A-00550B
LV-102A	VALVE, 1"TC DIAPHRAGM IIT 1"-F-419-6-36-TM17-A209
LV-102B	VALVE, .5"TC DIAPHRAGM IIT 1/2"-F-419-6-R2-36-A206
LV-103	VALVE, 1"TC DIAPHRAGM IIT 1"-F-419-6-36-TM17-A209
LSL-104	LEVEL PROBE, 1.5" MILLTRONICS C-235-S3A-00900B
TANK-200	JERRICAN, 2.5 GALLON NALGENE 2240-0025
JY-201A	RELAY, SPDT, ALLEN BRADLEY 700-HK36Z24-4 (24V DC)
JY-201B	CONVERTER, ANALOG TO DIGITAL LMI MP-100
PUMP-201	PUMP, METERING LMI E731-20S
FE-202	FLOW SWITCH SENSOR, .5"NPT EFECTOR SF3020
FS-202	FLOW SWITCH MONITOR, EFECTOR SR0127 (24V DC)
CHECK-203	CHECK VALVE, .5" SWAGELOK SS-CH9192-10
CV-204	VALVE, .5"TC DIAPHRAGM IIT 1/2"-F-419-6-TM17-36-M7-A206
TANK-300	JERRICAN, 2.5 GALLON NALGENE 2240-0025
JY-301A	RELAY, SPDT, ALLEN BRADLEY 700-HK36Z24-4 (24V DC)
JY-301B	CONVERTER, ANALOG TO DIGITAL LMI MP-100
PUMP-301	PUMP, METERING LMI E731-20S
FE-302	FLOW SWITCH SENSOR, .5"NPT EFECTOR SF3020
FS-302	FLOW SWITCH MONITOR, EFECTOR SR0127 (24V DC)
CHECK-303	CHECK VALVE, .5" SWAGELOK SS-CH9192-1
CV-304	VALVE, .5"TC DIAPHRAGM IIT 1/2"-F-419-6-TM17-36-M7-A206
TANK-400	JERRICAN, 2.5 GALLON NALGENE 2240-0025
JY-401A	RELAY, SPDT, ALLEN BRADLEY 700-HK36Z24-4 (24V DC)
JY-401B	CONVERTER, ANALOG TO DIGITAL LMI MP-100
PUMP-401	PUMP, METERING LMI E731-20S
FE-402	FLOW SWITCH SENSOR, .5"NPT EFECTOR SF3020
FS-402	FLOW SWITCH MONITOR, EFECTOR SR0127 (24V DC)
CHECK-403	CHECK VALVE, .5" SWAGELOK SS-CH9192-10
CV-404	VALVE, .5"TC DIAPHRAGM IIT 1/2"-F-419-6-R2-36-A206

